

Utilisation des bornes de recharge de l'Atrium 2016-2017

du 1er avril au 30 juin 2016

du 1er juillet au 30 septembre 2016

du 1er octobre au 31 décembre 2016

du 1er janvier au 31 mars 2017

du 1er avril 2016 au 31 mars 2017

Secteur Est

Station	Nbre de sessions	Temps de connexion	KWh
AAB-00021	78	133:54:00	452,352
AAB-00010	18	30:58:00	81,682
AAB-00006	43	105:33:00	544,728
AAB-00007	40	28:36:00	63,034
AAB-00016	53	82:33:00	329,152
AAB-00020	40	88:58:00	522,646
AAB-00003	49	110:16:00	461,647
AAB-00011	2	04:30	13,731
AAB-00005	77	162:48:00	1145,912
AAB-00009	13	17:55	81,411
AAB-00015	108	163:11:00	517,343
AAB-00014	153	23:02	47,392
AAB-00004	153	193:59:00	601,62
AAB-00012	48	46:13:00	140,848
AAB-00013	39	81:44:00	415,845
AAB-00017	18	40:28:00	43,326
Total secteur	942	1314:38:00	5 462,67

Secteur Est

Station	Nbre de sessions	Temps de connexion	KWh
AAB-00021	33	33:04:00	109,183
AAB-00010	21	24:03:00	37,684
AAB-00006	27	60:58:00	339,754
AAB-00007	9	11:50	23,716
AAB-00016	47	86:02:00	351,911
AAB-00020	66	149:00:00	857,289
AAB-00003	54	76:40:00	314,947
AAB-00011	29	63:44:00	407,226
AAB-00005	55	126:20:00	796,496
AAB-00009	10	06:59	21,254
AAB-00015	136	145:15:00	467,646
AAB-00014	95	52:01:00	57,841
AAB-00004	143	153:39:00	411,425
AAB-00012	19	37:54:00	133,67
AAB-00013	56	107:37:00	418,187
AAB-00017	6	06:29	23,028
Total secteur	806	1141:35:00	4 771,30

Secteur Est

Station	Nbre de sessions	Temps de connexion	KWh
AAB-00021	38	84:25:00	367,446
AAB-00010	85	61:36:00	86,278
AAB-00006	64	140:30:00	637,894
AAB-00007	142	50:54:00	129,675
AAB-00016	83	185:24:00	902,053
AAB-00020	103	172:45:00	935,097
AAB-00003	181	149:32:00	594,858
AAB-00011	90	28:14:00	74,667
AAB-00005	179	201:40:00	1320,179
AAB-00009	43	40:25:00	153,651
AAB-00015	271	163:08:00	477,026
AAB-00014	85	56:04:00	104,661
AAB-00004	163	184:14:00	581,75
AAB-00012	84	113:41:00	356,879
AAB-00013	89	162:32:00	591,92
AAB-00017	192	94:52:00	292,19
Total secteur Est	1892	1889:56:00	7 606,22

Secteur Est

Station	Nbre de sessions	Temps de connexion	KWh
AAB-00021	107	131:16:00	486,269
AAB-00010	363	117:35:00	230,139
AAB-00006	86	171:14:00	663,507
AAB-00007	122	63:52:00	99,557
AAB-00016	70	142:47:00	494,243
AAB-00020	62	145:41:00	535,101
AAB-00003	98	173:30:00	590,487
AAB-00011	52	27:13:00	49,493
AAB-00005	103	207:10:00	965,456
AAB-00009	61	55:09:00	170,568
AAB-00015	220	54:25:00	157,41
AAB-00014	449	96:59:00	230,506
AAB-00004	152	178:44:00	563,389
AAB-00012	79	144:23:00	497,079
AAB-00013	101	140:49:00	497,456
AAB-00017	251	123:07:00	336,354
Total secteur	2376	1973:54:00	6 567,01

Secteur Est

Station	Nbre de sessions	Temps de connexion	KWh
AAB-00021	256	382:39:00	1415,25
AAB-00010	487	234:12:00	435,783
AAB-00006	220	478:15:00	2185,883
AAB-00007	313	155:12:00	316,026
AAB-00016	253	496:46:00	2077,359
AAB-00020	271	556:24:00	2850,133
AAB-00003	382	509:58:00	1961,939
AAB-00011	173	123:41:00	545,117
AAB-00005	414	697:58:00	4228,043
AAB-00009	127	120:28:00	426,883
AAB-00015	735	525:59:00	1619,425
AAB-00014	782	228:06:00	440,4
AAB-00004	621	710:36:00	2158,184
AAB-00012	230	342:11:00	1128,476
AAB-00013	285	492:42:00	1923,408
AAB-00017	467	264:56:00	694,898
Total secteur	6016	6320:03:00	24 407,21

Secteur Ouest

Station	Nbre de sessions	Temps de connexion	KWh
AAA-215	2	04:20	18,896
AAA-073	4	09:56	29,954
AAA-093	1	01:14	3,808
AAA-088	7	05:58	25,14
Total secteur	14	21:28:00	77,79
Total Atrium	956	1336:06:00	5 540,46

Secteur Ouest

Station	Nbre de sessions	Temps de connexion	KWh
AAA-215	4	04:53	21,487
AAA-073	0	00:00	0
AAA-093	1	02:15	6,942
AAA-088	4	05:47	18,243
Total secteur	9	12:55:00	46,67
Total Atrium	815	1154:30:00	4 817,97

Secteur Ouest

Station	Nbre de sessions	Temps de connexion	KWh
AAA-215	8	14:25	66,985
AAA-073	1	02:45	8,666
AAA-093	2	00:46	2,205
AAA-088	1	02:13	7,357
Total secteur Ouest	12	20:09:00	85,21
Total Atrium	1904	1910:05:00	7 691,44

Secteur Ouest

Station	Nbre de sessions	Temps de connexion	KWh
AAA-215	3	08:51	27,47
AAA-073	0	00:00	0
AAA-093	4	07:38	23,912
AAA-088	0	00:00	0
Total secteur	7	16:29:00	51,38
Total Atrium	2383	1990:23:00	6 618,40

Secteur Ouest

Station	Nbre de sessions	Temps de connexion	KWh
AAA-215	17	32:29:00	134,84
AAA-073	5	12:41:00	38,62
AAA-093	8	11:53:00	36,87
AAA-088	12	13:58:00	50,74
Total secteur	42	71:01:00	261,06
Total Atrium	6058	6391:04:00	24 668,27